



Product Service

Attestation of Conformity

No. N8A 106361 0001 Rev. 00


Holder of Certificate: **Hitachi-Johnson Controls**
Air Conditioning, Inc
1-16-1, Kaigan Minato-ku
Tokyo
163-8001 JAPAN

Product: **Split Air Conditioners**
(AIR CONDITIONER HEAT PUMP
UNIVERSAL)

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. See also notes overleaf.

Test report no.: 64111190528201

Date, 2019-10-29


(Sam Yang)

Page 1 of 2

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.

TÜV SÜD Product Service GmbH • Certification Body • Ridlerstraße 65 • 80339 Munich • Germany

TÜV®



Product Service

Attestation of Conformity

No. N8A 106361 0001 Rev. 00

Model(s):

RAS-6.0UFESMH1/RPFC-6.0UFE1NH
(outdoor unit: RAS-6.0UFESMH1,
indoor unit: RPFC-6.0UFE1NH),
RAS-6.0UFESMH1/RCI-6.0UFE1NH
(outdoor unit: RAS-6.0UFESMH1,
indoor unit: RCI-6.0UFE1NH),
RAS-6.0UFESMH1/RPIH-6.0UFE1NH
(outdoor unit: RAS-6.0UFESMH1,
indoor unit: RPIH-6.0UFE1NH)

Brand:

HITACHI

Parameters:

Rated Voltage: 380-415V, 3N~ for outdoor unit;
220-240V~ for indoor unit
Rated Frequency: 50Hz
Rated Power:
7000W for RAS-6.0UFESMH1/RPFC-6.0UFE1NH;
7100W for RAS-6.0UFESMH1/RCI-6.0UFE1NH;
7200W for RAS-6.0UFESMH1/RPIH-6.0UFE1NH;
Rated Current:
12,00A for RAS-6.0UFESMH1/RPFC-6.0UFE1NH;
12,10A for RAS-6.0UFESMH1/RCI-6.0UFE1NH;
12,60A for RAS-6.0UFESMH1/RPIH-6.0UFE1NH
Protection Class: Class I
Degree of Protection: IPX4 for outdoor unit. IPX0 for indoor unit
Refrigerant: R-32

Tested according to:

EN 60335-1:2012/A13:2017
EN 60335-2-40:2003/A13:2012
EN 62233:2008

Page 2 of 2

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.